

Energy performance certificate (EPC)

2 Clarendon Court
Over Wallop
STOCKBRIDGE
SO20 8HU

Energy rating

E

Valid until:

13 April 2032

Certificate
number:

9013-8557-2510-7518-2632

Property type

B1 Offices and Workshop businesses

Total floor area


209 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

24 A

If typical of the existing stock

70 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Mechanical Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	108.33
Primary energy use (kWh/m ² per year)	641

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/8849-0589-8837-1750-7613\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Andrew Ling
Telephone	07767895320
Email	andrewjling@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008701
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Andrew Ling
Employer address	3 The Crescent, Salisbury, Wilts, SP2 8DF
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	7 April 2022
Date of certificate	14 April 2022